


### SUPPLEMENTAL/BID BULLETIN

Please be informed that during the Pre-Bid Conference held on March 4, 2026, a revision was made to the Specifications for the procurement of **Supply and Installation of Inverter and Non-Inverter Type Air Conditioning Units (Wall-Mounted and Ceiling Cassette Types)** with Bid Number **B-26-0008** under Purchase Request Number **26-0290**.

FROM		TO	
Item No.	Item Description	Item No.	Item Description
1	Airconditioning wall mounted type 1HP inverter  (14 units for 14 Board Members' Offices) with Remote controller and bracket 220-240V, 1Ph ,60Hz, R-32 Refrigerant, Energy Efficiency is ~4.20-4.6 CSPF	1	<b>Supply and Installation</b> – Airconditioning wall mounted type 1HP inverter  (14 units for 14 Board Members' Offices) with Remote controller and bracket 220-240V, 1Ph ,60Hz, R-32 Refrigerant, Energy Efficiency is ~4.20-4.6 CSPF
2	Supply and Installation – 2.0HP Wall Mounted Non-Inverter Type with Remote controller and bracket, R32, 24000BTU/h, 220-240V, 50-60Hz, 2P  (14 units for 14 Board Members' Staff Offices and 1 unit for Vice Governor's Lounge Area)	2	<b>65 meters – 10 AWG THHN/THWN Wire</b> <b>1 Length – 4” x 2.5” PVC Molding</b> <b>36 ft – Copper Tube 1/4” Liquid line and 3/8” Suction line</b>  Supply and Installation – 2.0HP Wall Mounted Non-Inverter Type with Remote controller and bracket, R32, 24000BTU/h, 220-240V, 50-60Hz, 2P
3	Supply and Installation - 5 TONNER Ceiling Cassette with Standard decorative Panel (white) Non-Inverter Type with wireless remote controller and, R410A Refrigerant, 220-240V, 50-60Hz, 3P  (2 units for SP Secretary Area, 3 units for SP Conference Area and 1 unit for Vice Governor's Conference Room)  Terms and Conditions:  1. Supply and installation shall commence only upon receipt of Notice to Proceed. 2. Scope of works to be undertaken shall conform to the specifications according to the purchase order. Inquire to the building custodian for the specific area of the installation. 3. In the event that the exact model or specification is unavailable, the Supplier shall provide a unit of higher or equivalent specifications at no additional cost to the Procuring Entity, subject to prior approval by the end-user or technical personnel. 4. All equipment needed in the implementation shall be provided by the supplier.	3	<b>65 meters – 10 AWG THHN/THWN Wire</b> <b>40 ft. – Copper Tube 1/4” Liquid line and 1/2” Suction line</b> <b>1 Length – 4” x 2.5” PVC Molding</b>  (14 units for 14 Board Members' Staff Offices and 1 unit for Vice Governor's Lounge Area)  Supply and Installation - 5 TONNER Ceiling Cassette with Standard decorative Panel (white) Non-Inverter Type with wireless remote controller and, R410A Refrigerant, 220-240V, 50-60Hz, 3P  <b>140 meters – 6 AWG THHN/THWN Wire</b> <b>85 ft. – Copper Tube 3/8” Liquid line and 7/8” Suction line</b>  (2 units for SP Secretary Area, 3 units for SP Conference Area and 1 unit for Vice Governor's Conference Room)  <b>800 meters – 6 AWG THHN/THWN Wire</b>  Terms and Conditions:





REPUBLIC OF THE PHILIPPINES  
PROVINCE OF DAVAO DE ORO  
OFFICE OF THE GOVERNOR

## BIDS AND AWARDS COMMITTEE

Cel #: 0962-241-8964/0946-470-6261



<p>5. The Supplier shall provide a one (1) year warranty on parts and services, and five (5) years warranty on the compressor, starting from the date of final acceptance.</p> <p>6. The Supplier shall provide free preventive maintenance and cleaning services of each installed air-conditioning unit for a period of one (1) year from the date of acceptance.</p> <p>7. Cleaning services shall be conducted quarterly, including filter cleaning, coil and blower maintenance, and system performance check.</p> <p>8. Any issue discovered during cleaning that affects performance shall be immediately repaired by the Supplier, free of charge, within the warranty period.</p> <p>9. All newly installed ACU must have complete components and accessories including but not limited to, magnetic contactor, brackets, circuit breakers, and wires.</p> <p>10. Calendar days to complete the installation is 15 days.</p>	<p>1. Supply and installation shall commence only upon receipt of Notice to Proceed.</p> <p>2. Scope of works to be undertaken shall conform to the specifications according to the purchase order. Inquire to the building custodian for the specific area of the installation.</p> <p>3. In the event that the exact model or specification is unavailable, the Supplier shall provide a unit of higher or equivalent specifications at no additional cost to the Procuring Entity, subject to prior approval by the end-user or technical personnel.</p> <p>4. All equipment needed in the implementation shall be provided by the supplier.</p> <p>5. The Supplier shall provide a one (1) year warranty on parts and services, and five (5) years warranty on the compressor, starting from the date of final acceptance.</p> <p>6. The Supplier shall provide free preventive maintenance and cleaning services of each installed air-conditioning unit for a period of one (1) year from the date of acceptance.</p> <p>7. Cleaning services shall be conducted quarterly, including filter cleaning, coil and blower maintenance, and system performance check.</p> <p>8. Any issue discovered during cleaning that affects performance shall be immediately repaired by the Supplier, free of charge, within the warranty period.</p> <p>9. All newly installed ACU must have complete components and accessories including but not limited to, magnetic contactor, brackets, circuit breakers, and wires.</p> <p>10. Calendar days to complete the installation is 15 days.</p>
---	---

For your information and guidance.

Thank you.

**IVAN KLEB N. ULGASAN, CESE**   
Chairperson  
Bids and Awards Committee

Received by the Bidder:

---



03/11/2026